

Hot Water Heating Boiler Operating Log



This boiler operating log is to be used in addition to the boiler manufacturer's operating requirements and instructions.

All operational tasks and tests must be conducted in accordance with the manufacturer's instructions by a trained and qualified individual.

Location: _____

Boiler #: _____

Name of qualified individual: _____

Year: _____

While recording the operating conditions on this log, visually inspect the controls, safety devices, relief valves, piping, and all associated equipment.

Any unusual or adverse conditions should be recorded, reported, and then corrected by a qualified technician.

Record the actual date items were performed in each column except WEEKLY tasks that are recorded with a check mark (✓).

Month	Weekly												Every 3 months		Annually			
	Test low water fuel cutoff and make up feed				Check circulating pumps and expansion tank				Inspect for leaks and clean area around boiler				Test safety valve by lifting lever by hand	Open and close boiler drain valve	Test burner operation	Clean boiler and burner	Verify operation of all safety devices and controls	Operating certificate inspection
	Week				Week				Week									
	1	2	3	4	1	2	3	4	1	2	3	4						
January																		
February																		
March																		
April																		
May																		
June																		
July																		
August																		
September																		
October																		
November																		
December																		

For more resources, visit <https://boilerre.travelers.com/resources>.